

A	ATS Panel for Lighting		
Sr.No.	ITEM	MAKE	QTY
1	TRANSFORMER INCOMER FEEDER		
	250A 4P MCCB 36 KA With Microprocessor Based Release (O/C, S/C, E/F) Protection	L&T	1
	Extended Rotary Handle	L&T	1
	Spreader Terminals	L&T	1
	250A 4P ATS	L&T	1
	Aux. Contact For Mccb	L&T	1
	Trip Contact For Mccb	L&T	1
	Under Voltage, Over Voltage Relay (27,59)	L&T	1
	MFM Meter With RS-485 Port	Reputed	1
	250 /5A	AE/Rishebh	4
	Indication Lamps R,Y,B	Veeco/Essbe	3
	6A SP MCB	L&T	2
	Emergency Stop Push Button	Reputed	1
	Aux. Contactor 2NO+2NC	L&T	1
	ON Delay Timer	L&T	1
	Auto/Manual Selector Switch	Reputed	1
2	DG INCOMER FEEDER		
	250A 4P MCCB 36 KA With Microprocessor Based Release (O/C, S/C, E/F) Protection	L&T	1
	Extended Rotary Handle	L&T	1
	Spreader Terminals	L&T	1
	Aux. Contact For Mccb	L&T	1
	Trip Contact For Mccb	L&T	1
	Under Voltage, Over Voltage Relay (27,59)	L&T	1
	MFM Meter With RS-485 Port	Reputed	1
	Cts 250/5A	AE/Rishebh	4
	Indication Lamps R,Y,B	Veeco/Essbe	3
	6A SP MCB	L&T	2
	Emergency Stop Push Button	Reputed	1
	Aux. Contactor 2NO+2NC	L&T	1
	ON Delay Timer	L&T	1
3	OUTGOING		
	SECTION-A		
	125A TPN MCCB With Spreder Terminals	L&T	2
	Extended Rotary Handle	L&T	2
	100A 4P MCCB With Spreder Terminals	L&T	2
	Extended Rotary Handle	L&T	2
	63A 4P MCCB With Spreder Terminals	L&T	2
	Extended Rotary Handle	L&T	2
	63A 4P MCB	L&T	2
	40A 4P MCB	L&T	2
	Aux. Contact For Mccb, Mcb	L&T	6
	6A SP MCB	L&T	6
	Indication Lamps ON	Veeco/Essbe	6
4	BUS BAR		
	250 A rating Al busbar of Electrolytic grade E		1
5	ENCLOSURE		
	CRCA sheet steel enclosure. Panel will be fabricated with 14/16SWG CRCA sheet steel and Dully Powder Coated with Siemens Gray and Chemical treatment.		1
	Wiring & Accessories (wire, thimbles, therminal block , pvc channel ferrules)		1