

<b>A</b>	<b>Auto Change Over Panel</b>		
<b>Sr.No.</b>	<b>ITEM</b>	<b>MAKE</b>	<b>QTY</b>
<b>1</b>	<b>TRANSFORMER INCOMER FEEDER</b>		
	1250A 4P MCCB 36 KA With Microprocessor Based Release (O/C, S/C, E/F ) Protection	L&T	1
	Extended Rotary Handle	L&T	1
	Spreader Terminals	L&T	1
	1250A ATS	L&T	1
	Aux. Contact For Mccb	L&T	1
	Trip Contact For Mccb	L&T	1
	Under Voltage, Over Voltage Relay (27,59)	L&T	1
	MFM Meter With RS-485 Port	Reputed	1
	Cts 1250/5A	AE/Rishebh	4
	Indication Lamps R,Y,B	Veeco/Essbe	3
	6A SP MCB	L&T	2
	Emergency Stop Push Button	Reputed	1
	Aux. Contactor 2NO+2NC	L&T	1
	ON Delay Timer	L&T	1
	Auto/Manual Selector Switch	Reputed	1
<b>2</b>	<b>DG INCOMER FEEDER</b>		
	1250A 4P MCCB 36 KA With Microprocessor Based Release (O/C, S/C, E/F ) Protection	L&T	1
	Extended Rotary Handle	L&T	1
	Spreader Terminals	L&T	1
	Aux. Contact For Mccb	L&T	1
	Trip Contact For Mccb	L&T	1
	Under Voltage, Over Voltage Relay (27,59)	L&T	1
	MFM Meter With RS-485 Port	Reputed	1
	Cts 1250/5A	AE/Rishebh	4
	Indication Lamps R,Y,B	Veeco/Essbe	3
	6A SP MCB	L&T	2
	Emergency Stop Push Button	Reputed	1
	Aux. Contactor 2NO+2NC	L&T	1
	ON Delay Timer	L&T	1
	Battery Charger	Reputed	1
<b>3</b>	<b>OUTGOING SECTION-A</b>		
	400A TPN MCCB With Spreder Terminals	L&T	3
	Extended Rotary Handle	L&T	3
	250A 4P MCCB With Spreder Terminals	L&T	3
	Extended Rotary Handle	L&T	3
	63A 4P MCCB With Spreder Terminals	L&T	3
	Extended Rotary Handle	L&T	3
	63A 4P MCB	L&T	2
	40A 4P MCB	L&T	2
	Aux. Contact For Mccb, Mcb	L&T	9
	6A SP MCB	L&T	9
	Indication Lamps ON	Veeco/Essbe	9
<b>4</b>	<b>BUS BAR</b>		
	1600 A rating Al busbar of Electrolytic grade E		1
<b>5</b>	<b>ENCLOSURE</b>		
	CRCA sheet steel enclosure. Panel will be fabricated with 14/16SWG CRCA sheet steel and Dully Powder Coated with Siemens Gray and Chemical treatment.		1
	Wiring & Accessories (wire, thimbles, therminal block , pvc channel ferrules )		1

<b>B</b>	<b>200 KVAR CAP. PANEL</b>		
<b>Sr.No.</b>	<b>ITEM</b>	<b>MAKE</b>	<b>QTY</b>
1	250A 3P MCCB With Spreder Terminals	L&T	1
	Extended Rotary Handle	L&T	1
	MFM Meter	Reputed	1
	Cts 250/5A	AE/Rishebh	3
	Indication Lamps R,Y,B, ON	Veeco/Essbe	3
	6A SP MCB	L&T	15
	6A 2P MCB	L&T	1
	63A 3P MCB	L&T	5
	32A 3P MCB	L&T	5
	16A 3P MCB	L&T	5
	APFC Relay	SELEC/HPL	1
	25 KVAR 3P Contactor	L&T	5
	10 KVAR 3P Contactor	L&T	5
	5 KVAR 3P Contactor	L&T	5
	25 KVAR CAPACITOR 3Ph,50Hz,440V MPP-H TYPE	L&T	5
	5 KVAR CAPACITOR 3Ph,50Hz,440V MPP-H TYPE	L&T	5
	10 KVAR CAPACITOR 3Ph,50Hz,440V MPP-H TYPE	L&T	5
	Aux. Contactor 2NO+2NC With Block	L&T	15
	ON Delay Timer	L&T	1
	Auto/Manaual Selector Switch	Reputed	1
	Indication Lamps ON	L&T	15
<b>2</b>	<b>MISCELLANEOUS ITEM</b>		
	Ext.Fan 220V	Reputed	2
	Temp. Relay	Reputed	2
	Space Heater	Reputed	2
	Limit Switch	Reputed	2
	Tube Light	Reputed	2
<b>3</b>	<b>BUS BAR</b>		
	250A rating Al. busbar of Electrolytic grade E91		1
<b>4</b>	<b>ENCLOSURE</b>		
	CRCA sheet steel enclosure. Panel will be fabricated with 14/16SWG CRCA sheet steel and Dully Powder Coated with Siemens Gray and Chemical treatment.		1
	Wiring & Accessories (wire, thimbles, thermanal block , pvc channel ferrules )		1